

Preparing Career Ready Graduates

Purchasing Services

4498 N. Brawley Ave. Fresno, CA 93722 Ph. (559) 457-3588 Fax (559) 457-6040 **BOARD OF EDUCATION**

Valerie F. Davis, President Keshia Thomas, Clerk Claudia Cazares Genoveva Islas Elizabeth Jonasson Rosas Carol Mills, J.D. Major Terry Slatic USMC (Retired)

SUPERINTENDENT

Robert G. Nelson, Ed.D.

June 15,2021

ADDENDUM No. 1 WAWONA MIDDLE SCHOOL CHILLER REPLACEMENT Informal Bid No. 1475-40397

NOTICE TO ALL BIDDERS

This Addendum is attached to and made a part of the above entitled specifications for Fresno Unified School District with a scheduled bid opening on June 18, 2020 prior to 2:01 P.M. All changes and/or clarifications will appear in **bold** type and deletions will be struck out in revised sentences.

Incorporate the following into your bid response.

I. <u>REFERENCE: SECTION 00 21 00-2 INFORMATION TO BIDDERS, JOB-WALK SIGN-IN SHEETS</u> *Add: Incorporate Job-Walk Sign-in Sheet.*

Attached is the Job-Walk Sign-In Sheet for the mandatory job-walk held on June 7, 2021, 9:00AM at Wawona Middle School. Only prime bidders are required to attend in order to be considered a responsive bidder.

II. REFERENCE: JOB WALK REQUEST FOR INFORMATION (RFI)

- Q.1. What will be the water volume of the hydronic system?
- A.1 Water volume of hydronic system, including new buffer tank/piping will be approximately 2,250 gallons
- Q.2. Will FUSD program existing controller?
- A.2. Yes, FUSD will provide programming for existing controller.
- Q.3. Where the chiller be stored at?
- A.3. Chiller will be delivered and stored at site of installation. Contractor is responsible for transportation of pump, and buffer tank from, 4600 N. Brawley Ave Fresno, CA. 93722 to site of installation. FUSD will load onto contractor's truck.
- Q.4. When will cooling be required?
- A.4. Chiller will need to provide cooling by 8/2/21

Acknowledge receipt and understanding of this addendum in designated area of the Bid Form.

Ann Boorz

Executive Director of Purchasing

ADDENDUM NO. 1, Page 1 of 1

MANDATORY Pre-Bid Conference / Job Walk Sign-in Sheet Informal Bid No. 1475-40397

Wawona Middle School Chiller Replacement

Pre-Bid Conference Date: June 7, 2021 @ 9:00 A.M.

THE DIG CONNECTICE DE	acc. June 7	, 2021 @ J.00 A.W.						
District Addres	is	Conference Loca	tion			D	istrict Conta	ct
Fresno Unified School District		in front of the Administrat	Ann Loorz, Executive Director of Purchasing					
Purchasing Department		Wawona Middle S	chool	4498 N. Brawley			rawley Ave	
4498 N. Brawley Ave		4524 N. Thorne	Fresno, CA 93722					
Fresno CA 93722		Fresno, CA 937	04	559-457-3582				
Contractor Information					umbe	r		
				(229)	790	- 3880	
Company Name: Strategic Mechanical								
city: Fresno					ner (estrates	junech.co	> ~
		Fischer, John, Da	initel					
Contractor Information					umbe	1000000		
Company Name: NEW ENGLAND SHEET META)				(<i>55</i> 4 Email		351-6	166	
	FREY			Bids	21	VESM.	Com	
Contact Name: MIKE Ewy								
Contractor Information					ımbe			
Company Name: Collius Electric				(<i>5</i> 59 Email) *****	317	- 875	<i>ا</i> لـ
City:	FRES	uo		Hhon	rus	e collin	nselectri	C.com
Contact Name:	Lane	Tuomas						
Contractor Information				Phone Nu	ımbe	,		
_	Fusis		()				
Company Name:			Email					
City:								
Contact Name:	Dan	y Anderson						
Contractor Information					ımbe			
Company Name:	Fus	<u> </u>		(Email) }}			
City:								
Contact Name:	Anv	Loon						