

Preparing Career Ready Graduates

Purchasing Services

Edward Collins, Executive Director 4498 N. Brawley Ave. Fresno, CA 93722 Ph. (559) 457-3588 Fax (559) 457-6040

March 16, 2021

BOARD OF EDUCATION

Valerie F. Davis, President Keshia Thomas, Clerk Claudia Cazares Genoveva Islas Elizabeth Jonasson Rosas Carol Mills, J.D. Major Terry Slatic USMC (Retired)

SUPERINTENDENT

Robert G. Nelson, Ed.D.

ADDENDUM No. 1 Bid 21-38

Centennial and Wishon Elementary Schools, and Scandinavian Middle School Multipurpose Room HVAC Upgrades

NOTICE TO ALL BIDDERS

This Addendum is attached to and made a part of the above entitled specifications for Fresno Unified School District with a scheduled bid opening on <u>March 25, 2021 prior to 2:01 P.M.</u> All changes and/or clarifications will appear in **bold** type and deletions will be struck out in revised sentences.

Incorporate the following into your bid response.

I. REFERENCE: IMEG, ADDENDUM No. 1

Add: Incorporate IMEG Addendum No. 1.

IMEG Addendum No. 1 dated March 02, 2021 which includes Addendum to the Project Manual(s) in your possession.

Instructions:

• Entire addendum may be downloaded from District Purchasing Web Site, under "Bid Opportunities". https://www.fresnou.org/dept/purchasing/Pages/Bid-Information.aspx

Acknowledge receipt and understanding of this addendum in designated area of the Bid Form.

Ann Lborz

Purchasing Manager

ADDENDUM NO. 1, Page 1 of 1



ADDENDUM # 1 Bid # 20-38

DATE:

March 02, 2021

PROJECT:

Fresno Unified School District

Centennial Elementary School MPR HVAC Wishon Elementary School MPR HVAC Scandinavian Middle School MPR HVAC

IMEG#

18003602.00, 18003597.00, 18003601.00

BID DUE DATE:

March 25, 2021

ENGINEER:

IMEG

901 Via Piemonte, Suite 400

Ontario, CA 91764 Phone: 909-477-6915

TO:

All Contract Document Holders of Record.

This Addendum forms a part of the bidding and construction documents. This Addendum supersedes and supplements all portions of the original bidding and construction documents dated **October 20, 2020 (plans) and January 15, 2021 (Technical Specifications)** with which it conflicts. Please attach this Addendum to the Project Manual(s) in your possession.

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED ON THE BID FORM. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.

A. GENERAL ITEMS

 ADD: Contractor shall videotape all training sessions with District personnel and provide District a copy on thumb drive and DVD with label indicating project name and training date

B. SPECIFICATIONS

- Reference Specification Section 15885 Air Filters
 - a. ADD: Requirement to specifications
 - 1). All filters for rooftop equipment shall be 2" pleated with MERV13 rating. Initial resistance not to exceed 0.30" w.g. at 500 FPM velocity. Filters shall be AAF/Flanders PREpleat M13 or District approved equal.

C. DRAWINGS

 Reference Scandinavian Middle School Addendum 2 drawings, sheet FA0.2, Fire Alarm Symbols: Change: Carbon monoxide detector base shall be Potter Model PAD100-SB in lieu of model PAD-4DB/6DB.

END OF ADDENDUM #1